



TEST CERTIFICATE

008

ACCESS CHAMBERS

DUCT

ENCLOSURES

NETWORK PROTECTION

STAKKAbOX MODULA 900mm x 600mm : EN124 CLASS B125 12.5 TONNES



Bodycote Materials Testing Ltd . North West Laboratory . Jefferson House . 5 Washington Centre, Broadway . Salford . M5 2UW
Tel: 0161 876 0277 . Fax: 0161 876 0279

Test Certificate

C4 Industries Ltd. ,
Yardley Road,
Knowsley Industrial Park
Kirkby
Liverpool
L33 7SS

REF No N704439 : Issue 2
Ord No Nil

Date Tested 17/05/97
Date Reported 23/03/00

Item - 900 x 600mm stacking inspection chamber called "Stakka box".
Prepared for inserted pipes.

Specification- BS EN 124 B125

LOAD TEST - Client requirements

| | Position | Details | Comments |
|---------------|----------|---------|--|
| 1: Proof Load | N/A | N/A | Acceptable. Maximum displacement 0.15mm. |

Certificate Comments

Testing was carried out in accordance with the requirements of BS EN 124
A measurement reference point was selected and the height of the 3 stacked units determined.
A load of 100kN was applied to a 200mm diameter test block and sustained for a period of 10 seconds. This was repeated a further five times, and the reference measurement noted.
The assembly was subsequently loaded to 125kN and the load sustained for a period of 30 seconds.
After a period of 20 seconds (minimum), the reference point was measured again.
Acceptance is based on the difference between original and final measurement of the reference point.
(The load was applied to a flat steel plate, to simulate access chamber cover)

Tested by D.R.Vickers I Eng A.M.I.M.

.....
For and on authority of
Bodycote Materials Testing Ltd

ANDREW CLARK
I Eng. AMIM
General Manager